



सत्यमेव जयते

Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
English Bazar Fire Station, Ghorapir, Malda. Pin :- 732101

Memo No.: FSR/IND/WB/FES/20182019/18131

Date : 29-05-2026

From :
Divisional Fire Officer
Maldah Division,
West Bengal Fire & Emergency Services

To :
THE HOLY ANGELS ENGLISH ACADEMY
Kandaran,Samsi,Dist.-Malda

Sub : Renewal of Fire Safety Certificate for an existing G+III storied Educational building in the name & style" THE HOLY ANGELS ENGLISH ACADEMY" at Vill.- Kandaran, P.O.- Samsi, P.S.- Chanchal, Dist.-Malda.

FSR/IND/WB/FES/20182019/18131

This is in reference to your AIN 211912606300010897 dated 26-May-2026 regarding Renewal of Fire Safety Certificate for an existing G+III storied Educational building in the name & style" THE HOLY ANGELS ENGLISH ACADEMY" at Vill.- Kandaran, P.O.- Samsi, P.S.- Chanchal, Dist.-Malda. .

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

1. Driveway must be free from any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
2. The interior finish decoration of the building shall be made with low flame



Samsi
The Holy Angels English Academy
O.. Kandaran (Samsi), Dist.- Malda

Principal
PRINCIPAL
THE HOLY ANGELS ENGLISH ACADEMY
Kandaran, Chanchal, Malda,
W.B.-732139
CBSE Aff No.-2430209, Code-15740

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300010897

spread material conforming to the I.S. Specification.

3. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.

4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.

5. A Fire Control Room including a CCTV system will have to be maintained, which observe all floors of the building.

6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable places of the building.

7. The employees and security staff shall be conversant with installed Fire Fighting Equipment of the building and to operate in the event of Fire and Testing.

8. Mock Fire practice and Evacuation Drill shall be performed periodically with participation of all the occupants of the building.

9. The sealed Electrical ducts vertically and horizontally at each floor level by fire resisting materials to be checking periodically.

10. Unauthorized cooking arrangement in any floor of the building using L.P.G., Kerosene etc. shall not be permitted and Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.

11. First-Aid Fire Fighting system shall be provided as per I.S. specification.

12. Arrangement shall have to be made for regular checking, testing and maintenance of all the firefighting installation in the building to keep them in perfectly good working condition at all the times.

13. If required the old electrical lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.

14. Periodical flashing of water from the Hydrant lines shall be made to maintain the efficient working performance of above-mentioned system.

15. The Fire Safety Audit & Electrical Audit to be conducted at regular interval and to be recorded in the fire prevention maintenance register.

16. Good housekeeping to be maintained regular basis.

N.B.- The following recommendation shall be complied within three (3) months from the date of issue of this certificate to ensure life and fire safety-security:

i) Manually operated Electrical Fire Alarm System with at least three numbers of break glass type call boxes fitted with Hooters at each floor connecting with visual panel board shall be made in Control Room. The Control Room shall be located at entrance of ground floor of the building.

ii) As per last RFSC condition, the establishment must have its departmentally approved plan drawing issued or if already available, submit it to the department. Any addition, alteration, extension, deviation and changes the nature of use of the buildings in respect of the approved plan drawing, without prior permission from this office, this Fire Safety Certificate will be treated as cancelled.



Secretary
The Holy Angels English Academy
O.- Kandarán (Sambal), Dist.- Malda

Principal
PRINCIPAL
THE HOLY ANGELS ENGLISH ACADEMY
Kandarán, Chanchal, Malda,
W.B.-732139
CBSE Aff. No. 2430209, Code-15740

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300010897

This Fire Safety Certificate is valid for 3 (Three) years from the date of issue of this certificate and have to be renewed within validity period.

A certificate is to be obtained from the **Director General, West Bengal Fire & Emergency Services** for performance of all the Fire & Life Safety arrangements and installations of the building.

Valid Upto : 27-May-2029

Memo No.:
FSR/IND/WB/FES/20182019/18131


Secretary
The Holy Angels English Academy
P.O. - Kandarān (Semi), Dist.- Malda


PRINCIPAL
THE HOLY ANGELS ENGLISH ACADEMY
Kandarān, Chanchal, Malda,
W.B.-732139
CBSE Aff. No.-2430209, Code-15740



Signature valid

Digitally Signed.
Name: SHILPA NANDA BARMAN
Date: 29-May-2019 12:55:49
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300010897